

EC-Type Examination Certificate

No. M6A 097929 0008 Rev. 00

Holder of Certificate: **Elco (Tianjin) Electronics Co., Ltd.**

No. 12, 4th XEDA Branch Road
Xiqing Economic Development Area
300385 Tianjin
PEOPLE'S REPUBLIC OF CHINA


Product: **Safety Relays**
Safety Relay Emergency Stop Module

This EC Type Examination Certificate is issued according to Article 12(3) b or 12(4) a of Council Directive 2006/42/EC relating to machinery. It confirms that the listed Annex-IV equipment complies with the principal protection requirements of the directive. It refers only to the sample submitted to TÜV SÜD Product Service GmbH for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: ET91241T

Valid until: 2027-09-29

Date, 2022-09-30



(Jiayi Dong)

EC-Type Examination Certificate

No. M6A 097929 0008 Rev. 00

Model(s):

SR22-Series

For nomenclature see below

Parameters:

Rated input voltage

AC/DC 24V

Response time

20ms

Degree of Protection

Housing IP 40

Terminals IP 20

Nomenclature of SR22

SR22-xy/24VUC/ESC

with:

x Number of NO Contacts

y Number of NC Contacts