



Product Service

# CERTIFICATE

No. Z10 097929 0007 Rev. 00

**Holder of Certificate:** **Elco (Tianjin) Electronics Co., Ltd.**

No. 12, 4th XEDA Branch Road  
Xiqing Economic Development Area  
300385 Tianjin  
PEOPLE'S REPUBLIC OF CHINA

**Certification Mark:**



**Product:** **Safety Relays**  
**Safety Relay Emergency Stop Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** ET91241T

**Valid until:** 2027-09-29

**Date,** 2022-09-30

( Jiayi Dong )

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFIKAT ◆ CERTIFICATE



Product Service

# CERTIFICATE

No. Z10 097929 0007 Rev. 00

## Parameters:

Rated input voltage	AC/DC 24V
Response time	20ms
Degree of Protection	Housing IP 40 Terminals IP 20

## Tested according to:

ISO 13849-1:2015 (Cat.4, PL e)  
EN ISO 13849-1:2015 (Cat.4, PL e)  
IEC 61508-1:2010 (SIL 3)  
IEC 61508-2:2010 (SIL 3)  
EN 61508-1:2010 (SIL3)  
EN 61508-2:2010 (SIL 3)  
IEC 61326-3-1:2017  
EN 61326-3-1:2017

## Model(s):

### SR22-Series

For nomenclature see below

## Nomenclature of SR22

### SR22-xy/24VUC/ESC

with:

x	Number of NO Contacts
y	Number of NC Contacts